

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0410:152 Page 1 of 1

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621  
\*Contact: Bob Misiuk (714) 670-3251 Fax (714) 690-7890

**DESIGN:** Model HCP-201, HCP-202, HCP-204 and HCP-204E fire alarm control units. Non-coded; automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory service. System components:

HCP-201,-202,-204,-204E	Main Fire Alarm Assembly
HDM-204	Initiating & NAC Zones
HRM-204, HRM-208	Relay Module
HPR-100	Polarity reversal & City Tie
HDACT-100	DACT
BB-815, BB-816	Enclosure

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation instructions Manual for details.

**NOTE:** For *Fire Alarm Verification Feature*, the maximum Retard/Reset/Restart period shall not exceed 30.0 seconds.

**XLf:** 07165-1477:109

\*Rev. 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 14, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager